Essex County Highways West End Depot Monthly Health & Safety Inspection

Date:	NOV 29	12016	Inspected By: (Print)	DAVE	VARNEY
Time:	11: PM	2	· ·	22	

Emergency Lights	Ok	Repair	Date Repaired
West Wall	1		
East Wall			
Smoke Alarm		DEAD BATTERY	NOU 30/2016
Office			<u> </u>
CO2 Detector			
Office			
Fire Extinguishers			
Southwest Mandoor	. V	ALSING	
Norteast Mandoor	1		
Southside Between O/H Doors			
Fuel Pumps	V	NO INSPECTION TAG	
Salt Dome			
Lights			
Fan	L		

First Aid Kit	Yes	No	Date Repaired
St. John's Ambulance First Aid Manual	/		
1 Card of Safety Pins	V		
24 Adhesive Dressings Individually Wrapped	V		
12 Sterlie Gauze Pads (3 Sq. Inches)	V		
4 Rolls of 2 Inch Gauze Bandage		1 MISSING	
4 Rolls of 4 Inch Gauze Bandage	V		
4 Sterile Surgical Pads Suitable for Pressure Dressings (Individually Wrapped)	/		
6 Triangular Bandages	V		
2 Rolls of Splint Padding		No	
1 Roll-up Splint		No	

HYDROGEN PEROXIDE

OUT OF DATE (EXP)

Inspected By: (Print) DAVE VARWEY
(Sign)

Essex County Highways

WORKPLACE INSPECTION RECORDING FORM

AREA COVERED:	lest Eurol		TIME OF I	TIME OF INSPECTION: 1/2m	1/ pm :
				FOR FUTURE FOLLOW-UP	W-UP
ITEM (and location of Item)	HAZARD(S) OBSERVED	REPEAT ITEM YES/ NO	RECOMMENDED ACTION	ACTION TAKEN	DATE
DUST TORM LIGHT	NORTHEAST CORNER		NEOS REPAIR.	BULB CHANGED	
	of Building Going				
	ON AND OFF.				
BLOCK HEATER PLUG	TRIPING BREAKER IN		NED REPAIR.	43214431	
	MAIN PANEL		BREAKER IS OFF)		
EYE WASH REFILL	EXP IN 2010			REPLACED	
The state of the s					
A A STATE OF THE S					
		-			
TO: 1) Department Head	_		Š.		
			INSPECTED BY: フイング	DAUG VARNEY KIVIT	(

3) Joint Occupational Health & Safety Committee

2) Personnel Co-ordinator